

POOL OPERATORS LOG

DAY _____ DATE _____ 2004

Time															Notes	Chemicals Added	Mechanical Log			
Swirl Pool																	E.B.	Evening		
Free Chlorine																Desired CL (min. 3.0)				
pH																Desired pH 7.5		GPM (swirl)		
Soda Ash																Temp. 103 - 104 F		FILTER #1		
Chlorine Rate																		FILTER #2		
Tank Weight #1																Notify Maintenance		CI PUMP		
Tank Weight #2																when Tank Weight is		BACKWASH		
Water Temp.																15 lbs or less				
Chlorine Detector <small>ppm</small>																				
Leisure Pool																				
Free Chlorine																Desired CL (min. 1.5)		GPM(Leisure)		
pH																Desired pH 7.5		FILTER #1		
Soda Ash																Temp. 90 F		FILTER #2		
Chlorine Rate																		CI PUMP		
Strantrol-no red lights. Probes in water																		BACKWASH		
Main Pool																				
Free Chlorine																Desired CL (min. 1.0)		GPM(Main)		
pH																Desired pH 7.5		FILTER #1		
Acutrol pH																Temp. 83 - 84 F		FILTER #2		
ORP																		VAC. PRESS		
Acutrol green flow light on. Probes in water.																		CI PUMP		
Water Temp.																Sauna desired temp.		BACKWASH		
Initial																80-85 C		& STRAINER		